

DOCUMENT 00904 – ADDENDUM NUMBER FOUR

DATE: January 4, 2021

PROJECT: **MHA BUS DUCT, SWITCHBOARD & EMERGENCY POWER FEED RENOVATION**
1301 Adams Avenue
Montgomery, Alabama 36104

FROM: CCR Architecture & Interiors
2920 First Avenue South
Birmingham, Alabama 35233

TO: Prospective Bidder

This addendum forms a part of the Contract Documents and modifies the original Construction Documents Dated August 19, 2020, as noted below.

CLARIFICATIONS:

1. **Fire Sprinkler clarification** – Regarding the modification of sprinkler heads mentioned in Addendum Three, schedule and coordinate accessing apartment units next to the utility rooms with Montgomery Housing Authority (MHA) property management. Remove and patch existing soffits and chases to match existing construction as required to access existing sprinkler water pipes, as part of the Base Bid.

END OF DOCUMENT 00904