



ADDENDUM ONE

DATE: February 27, 2026
TO: All Respondents
FROM: Sheila Brown, Procurement/Contract Administrator
RE: **ADDENDUM #1 Question and Answer**

Are yall seething water meters and back flows and do you need a one year maintenance quote including with price

MHA Response:

For irrigation water, provide one secondary meter for irrigation behind the property's existing domestic water meter. Multiple water meters and backflows are not required.

Regarding landscape maintenance, Yes, include a one year maintenance allowance in the Base Bid as described in Spec Section 329100 Landscape Maintenance.

We are grateful for your interest in doing business with our Agency and we look forward to receiving a bid from your company.