



ADDENDUM SEVEN

DATE: March 6, 2026
TO: All Respondents
FROM: Sheila Brown, Procurement/Contract Administrator
RE: **ADDENDUM #7 Clarifications to Addendum 6**

The Response below provides further clarification to addendum 6.

- 1.) What kind of hardware is desired for the pedestrian gates? Will they get access controls too? Will they need to be able to be locked and unlocked from the office?

ACCESS CONTROL FOR PEDESTRIAN GATES: Provide keypads, locks and panic bars on all new pedestrian gates along the property boundary (on both Terminal Road & Mobile Road).

We are grateful for your interest in doing business with our Agency and we look forward to receiving a bid from your company.